

MINIMUM STANDARDS AND DIMENSIONS											
MATERIAL	PUBLIC STREETS								PRIVATE WAYS ¹		
	Arterial	Collector	Urban Subcollector	Rural Subcollector	Urban Access	Rural Access	Industrial/Commercial	Service	Gravel 1 Lot	Gravel 2-6 Lots	Paved 7-10 Lots
Aggregate Sub-Base Courses											
Type E	18'	12"	12"	9"	9"	9"	12"	6"	-	-	-
Type D	15"	15"	15"	12"	12"	12"	15"	15"	12"	15"	15"
Crushed Aggregate Base Course											
1 1/2" Crushed, Type A, or Reclaimed	3"	3"	3"	3"	3"	3"	3"	3"	3"	3"	3"
Hot Bituminous Pavement:											
Total Thickness Compacted	6"	5"	5"	4"	4"	4"	5"	4"	-	-	2 1/2"
Base Course, B-Mix	2 - 2"	2 - 1 3/4"	2 - 1 3/4"	2 1/2"	2 1/2"	2 1/2"	2 - 1 3/4"	2 1/2"	-	-	1 1/2"
Base Course, HMA 19.0 mm	2 - 2"	3 1/2"	3 1/2"	2 1/2"	2 1/2"	2 1/2"	3 1/2"	2 1/2"	-	-	-
Surface Course, C-Mix	2"	1 1/2"	1 1/2"	1 1/2"	1 1/2"	1 1/2"	1 1/2"	1 1/2"	-	-	1"
Surface Course, HMA 9.5 mm	2"	1 1/2"	1 1/2"	1 1/2"	1 1/2"	1 1/2"	1 1/2"	1 1/2"	-	-	2 1/2"
Bituminous Concrete Sidewalk:											
Crushed Aggregate Base Course		10"	10"		10"						
Pavement Surface Course		2 - 1"	2 - 1"		2 - 1"						
C-Mix or HMA 9.5 mm											

NOTE: ALL METHODS AND MATERIALS TO MEET SPECIFIED CURRENT M.D.O.T. STANDARDS