

Single-Family Dwelling Fire Sprinkler Annual Inspection/ Test Form

Address : _____

Gorham, Maine

Date : _____

Y N N/A

- ☐ ☐ ☐ Have there been any changes to the dwelling that could affect the sprinkler coverage since the last inspection? [Adding/ removing walls/ ceilings (sheetrock or suspended), adding ceiling fans] **If yes, please explain below**
- ☐ ☐ ☐ Are all sprinkler heads clear of obstructions? **If no, please explain below**
- ☐ ☐ ☐ Are all sprinkler heads and recessed head cover plates free of non-factory applied paint, caulking and/ or other material? **If no, please explain below**
- ☐ ☐ ☐ Are there any leaks present? [At/ near sprinkler heads, at/ near exposed elbows/ joints, along exposed piping] **If yes, please explain below**
- ☐ ☐ ☐ Are all control valves OPEN? **If no, please explain below**
- ☐ ☐ ☐ Are all electronic switches in the ON position? **If no, please explain below**
- ☐ ☐ ☐ Is the tank FULL? **If no, please explain below**
- ☐ ☐ ☐ Do all control valves operate freely? **If no, please explain below**
- ☐ ☐ ☐ If the system has an outside bell and flow switch, do they operate when tested? **If no, please explain below**
- ☐ ☐ ☐ Does the system have an Anti-freeze loop? If yes, date of last test of solution _____

EXPLAIN: _____

By signing, I attest that I have conducted an inspection of the sprinkler system in my residence accordance with training provided by the Gorham Fire Department and that the information I provided is accurate. I also acknowledge that I accept all liability for any failure of the sprinkler system and the system must be inspected by a sprinkler technician licensed by the State of Maine prior to sale of the dwelling.

Print Name: _____

Signed: _____