

MINIMUM STANDARDS AND DIMENSIONS												
	PUBLIC STREETS								PRIVATE WAYS <sup>1</sup>			
<b>MATERIAL</b>	<b>Arterial</b>	<b>Collector</b>	<b>Urban Subcollector</b>	<b>Rural Subcollector</b>	<b>Urban Access</b>	<b>Rural Access</b>	<b>Industrial/Commercial</b>	<b>Service</b>	<b>Gravel 1 Lot</b>	<b>Gravel 2-6 Lots</b>	<b>Paved 7-10 Lots</b>	<b>Paved 25 Lots</b>
Aggregate Sub-Base Courses												
Type E	18'	12"	12"	9"	9"	9"	12"	6"	-			9"
Type D	15"	15"	15"	12"	12"	12"	15"	15"	12"	15"	15"	12"
Crushed Aggregate Base Course	3"	3"	3"	3"	3"	3"	3"	3"	3"	3"	3"	3"
1 1/2" Crushed, Type A, or Reclaimed												
Hot Bituminous Pavement:												
Total Thickness Compacted	6"	5"	5"	4"	4"	4"	5"	4"	-	-	2 1/2"	3 1/2"
Base Course, B-Mix	2 - 2"	2 - 1 3/4"	2 - 1 3/4"	2 1/2"	2 1/2"	2 1/2"	2 - 1 3/4"	2 1/2"	-	-	1 1/2"	2"
Base Course, HMA 19.0 mm	2 - 2"	3 1/2"	3 1/2"	2 1/2"	2 1/2"	2 1/2"	3 1/2"	2 1/2"	-	-	-	2"
Surface Course, C-Mix	2"	1 1/2"	1 1/2"	1 1/2"	1 1/2"	1 1/2"	1 1/2"	1 1/2"	-	-	1"	1 1/2"
Surface Course, HMA 9.5 mm	2"	1 1/2"	1 1/2"	1 1/2"	1 1/2"	1 1/2"	1 1/2"	1 1/2"	-	-	2 1/2"	1 1/2"
Bituminous Concrete Sidewalk:												
Crushed Aggregate Base Course		10"	10"		10"							10"
Pavement Surface Course C-Mix or HMA 9.5 mm		2 - 1"	2 - 1"		2 - 1"							1"

**NOTE: ALL METHODS AND MATERIALS TO MEET SPECIFIED CURRENT M.D.O.T. STANDARDS**